

GEO – TECHNICAL CONSULTANT

(Division of MACHTECH)

Plot no. 61 Vikaskung, Near Tower, Dibiyapur – 206244, District – Auraiya, Uttar Pradesh (India)

E-mail: machtechtools55@gmail.com , Mobile Number :- 9265018387

Ref : MTL/WL/23-24/43

Date 18.04.2023

REPORT ON GEO-PHYSICAL RESISTIVITY LOGGING OF BOREHOLE

A deep borehole was drilled by working agency M/s. M/s. VTL- GAJA (JV) as a part of their scope of work of development of Tubewell under Jal Jeevan Mission Project of SWSM, MTL conducted a Geophysical Continuous logging in the above borehole.

Village Name	Aani baijal
Block	Gauriganj
District	Amethi, U.P.
Logged Depth	153.5 Mtr BGL
Type of Log	Continuous well logger (SP, N16 (SN), N64 (LN) & LAT)
Machine Used	IGIS
Logging Date	17.04.2023

The following aquifer zones have been deciphered with the help of logging machine.

Sr. No.	Depth Range (mtr BGL)	Thickness (mtr)	Expected Quality
1	25 – 32	7	Good
2	50 – 54	4	Good
3	68 – 75	7	Good
4	79 – 82	3	Good to Moderate
5	92 – 96	4	Good to Moderate

Rw –13.7 Ohm mtr and Rm –11.5 Ohm mtr

- Logging performed as per SWSM guidelines.
- Groundwater quality interpreted by firm as per their logger calibration

For Geo-Technical Consultant,



Authorised Signatory

GSh
18/04/23