



aarvee associates
architects engineers & consultants pvt. ltd.



QUALITY MANAGEMENT SYSTEM

Format No :
KPTL/232221F/00023

DEPTH OF STARTA

PROPOSED ASSEMBLY DETAILS

Block- Sakit

GP- Dattapuz Kunjipuz

SL.

DPR Details -

Lowering Date - 15/10/2023

- | | | |
|----|---------------------------|-----------------|
| 1 | Water Discharge in LPM - | <u>330 LPM</u> |
| 2. | Bore well Drilling dia- | <u>500 mm φ</u> |
| 3. | Bore well Drilling depth- | <u>110m</u> |

LOGGING REPORT

Depth- 103

Date- 10/10/2023


SL.	Depth Range	Thickness	Remarks
1	<u>46-56</u>	<u>10</u>	<u>fine to medium Sand</u>
2	<u>72-80</u>	<u>08</u>	<u>fine to medium Sand</u>
3	<u>85-89</u>	<u>04</u>	<u>" "</u>
4			
5			
6			
7			
8			
9			
10			
11			

Assembly Details

⇒ Total Assembly = 18 + 77.020
= 95.020m

Proposed Assembly for Lowering

- | | | |
|-----|----------------------------|-----------------|
| 1. | 300mm dia MS Plain Pipe- | |
| 2. | 200mm dia MS Plain Pipe | <u>77.020 m</u> |
| 3. | 200mm dia MS Slotted Pipe- | <u>18.00 m</u> |
| 4. | 200mm dia LCG Pipe - | |
| 5. | 300/200 mm dia Reducer - | |
| 6. | MS Bail Plug- | <u>01</u> |
| 7. | MS Ring 300mm- | |
| 8. | MS Ring 200mm- | <u>16</u> |
| 9. | MSSI Clamp- | <u>01</u> |
| 10. | Centre Guide - | <u>05</u> |
| 11. | TW Assembly Support- | <u>01</u> |
| 12. | MS Well Cap - | <u>01</u> |
| 13. | Pea Gravel Packing- | <u>1887 cum</u> |



Prachin
KPTL 16/10/2023
Prach

प्रिंस राजपुत्र
TPI
Lowering work
executed as per
assembly chart.
DPR

CLIENT (UPJN)