

QUALITY MANAGEMENT SYSTEM

Format No : KPTL/232221F/00023



aaavee associates
architects engineers & consultants pvt. ltd.



DEPTH OF STARTA

PROPOSED ASSEMBLY DETAILS

Block- Nidhali kalan.
GP- Aharmai

SL. DPR Details -

- Lowering Date - 23/06/2023
- 1 Water Discharge in LPM - 340
- 2 Bore well Drilling dia- 500mm
- 3 Bore well Drilling depth- 110 mtr.


LOGGING REPORT

Depth- SL.	Depth Range	Date- Thickness	Remarks
1			
2	<u>30-44</u>	<u>14 mtr.</u>	
3			
4			
5			
6			
7			
8			
9			
10			
11			

Assembly Details

Proposed Assembly for Lowering

- 1. 300mm dia MS Plain Pipe-
- 2. 200mm dia MS Plain Pipe - 39.50 mtr.
- 3. 200mm dia MS Slotted Pipe- 14.00mtr.
- 4. 200mm dia LCG Pipe -
- 5. 300/200 mm dia Reducer -
- 6. MS Bail Plug- 1
- 7. MS Ring 300mm-
- 8. MS Ring 200mm- 10
- 9. MSSl Clamp- 1
- 10. Centre Guide - 2
- 11. TW Assembly Support- 1
- 12. MS Well Cap - 1
- 13. Pea Gravel Packing-



Shubham
KPTL

TPI
TPI

CLIENT (UPJN)

Lowering work executed by per assembly chart.