




DEPTH OF STRATA

PROPOSED ASSEMBLY DETAILS

UP-Nagda 924 - Block Nidhauri Kalan



DRP DETAILS

1	Lowering Date	21/01/23
2	Water Discharge in LPM	380 LPM
3	Bore well Drilling	110 MTR
4	Drilling Depth 500MM Dia	170m
5	600MM Dia	57.59m

1- LOGGING REPORT

Sl	Depth Logged- Depth Range (Mts)	MBR	Thickess in Mtr	Date of Logging	Remarks
1	27-46		1.9M		
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					

ASSEMBLY DETAILS

m Dia Housing Pipe A.G.L.	0.5m + 0	m
m Dia Housing Pipe		m
m Dia Reducer Pipe	to	m
m Dia Pipe	to	m
m Dia Pipe	to	m
m Dia Pipe	to	m
m Dia Pipe	to	m
m Dia Pipe	to	m
m Dia Pipe	to	m
m Dia Pipe	to	m
m Dia Pipe	to	m
m Dia Pipe	to	m
TOTAL ASSEMBLY	0.5 + 57.59	m

3- Proposed Assembly for Lowering

(1) 300MM DIA MSERW PLAIN PIPE	=	
(2) 200 MM DIA MSERW PLAIN PIPE	=	40.01
(3) 150MM DIA MSERW PLAIN PIPE	=	
(4) 300/150 MM DIA REDUCER	=	
(5) 200/150 MM DIA REDUCER	=	
(6) 300MM DIA MSERW SLOTTED PIPE	=	18.08
(7) 300 MM DIA WELL CAP	=	
(8) 200MM WELL CAP	=	1
(9) 200MM DIA CENTER GUIDE	=	3
(10) GRAVEL PACKING	=	
(11) 600 MM DIA BORE DIGGING	=	
(12) 500 MM DIA BORE DIGGING	=	
TOTAL ASSEMBLY	=	0.5 + 57.59 = 58.09 Mtrs.

JMC

TPI

Lowering work executed as per assembly chart

CLIENT (UPJN)