



aarvee associates architects engineers & consultants pvt. ltd.

KALPA-TARU

DEPTH OF STARTA

PROPOSED ASSEMBLY DETAILS

Block - Shetaldpur
GP - Phasa Majara Kabisphur

SL.	DPR Details -
1	Lowering Date - 24/05/2023
2	Water Discharge in LPM - 220 LPM
3	Bore well Drilling dia - 500 mm
	Bore well Drilling depth - 100m

LOGGING REPORT


Depth - 100	Date - 20/04/2023		
SL.	Depth Range	Thickness	Remarks
1	26-42m		
2	48-52m		
3	57-63m		
4	71-80m		
5			
6			
7			
8			
9			
10			
11			

Assembly Details

Total Assembly - 84.1m

Proposed Assembly for Lowering

1.	300mm dia MS Plain Pipe	65.990m
2.	200mm dia MS Plain Pipe	18.02m
3.	200mm dia MS Slotted Pipe	
4.	200mm dia LCG Pipe	
5.	300/200 mm dia Reducer	
6.	MS Ball Plug	01
7.	MS Ring 300mm	15
8.	MS Ring 200mm	01
9.	MSSI Clamp	03
10.	Centre Guide	01
11.	TW Assembly Support	01
12.	MS Well Cap	
13.	Pea Gravel Packing	



Lowering work executed as per assembly chart.

CLIENT (UPJN)

TPI

KPTL