

GSTIN : 09AEGPG8985L2ZJ



# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

12-A, Shree Nagar Colony, Ferozabad Road, Agra- 202008  
 Mob: 9781103000, 9784825420. Email: gwsc\_agra@yahoo.com

of No. .... Date 8.2.23

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

### DETAIL OF WATER BEARING ZONES

Name Of Agency: P.N.C. Badam Chakwat Goro well uylaw  
 Village: Ambhayaapur Block: Ambhayaapur  
 District: Badam Logging Depth: 130 mt.  
 Drilling Depth: 130 mt. Water Level: 17 mt.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 17	Dry Sand	
3	17 - 20	clay	
4	20 - 25	fine sand	
5	25 - 33	clay loam	
6	33 - 44	Medium Sand	Med + good
7	44 - 51	clay loam	
8	51 - 57	Medium Sand	Med + good
9	57 - 65	clay loam	
10	65 - 75	Medium Sand	Med + good
11	75 - 78	clay loam	
12	78 - 90	Medium Sand	Med + good
13	90 - 97	clay loam	
14	97 - 113	Medium Sand	Med + good
15	113 - 120	clay loam	
16	120 - 130	Medium Sand	Med + good
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

*Singh*  
 Geophysicist

Specializations in

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,  
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.