

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9781163000, 9794625420. Email : gwsc_agra@yahoo.com

of No.


Date 25.2.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency P.N.C. S.P.M.L. JV Badami
 Village Archi Block Asafpur
 District Badami Logging Depth 140 mtr
 Drilling Depth 140 mtr Water Level 17 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-15	Dry Sand	
3	15-25	clay	
4	25-48	Medium Sand	Medium
5	48-53	claystone	
6	53-83	Medium sand	Medium
7	83-90	claystone	
8	90-138	Medium Sand	Medium
9	138-140	claystone	
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

[Signature]
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.