



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No

Date 19.5.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- P.N.C. SPM L-IV, Bhejwati, Dist. Agra

Village- Sarsa, Khand Block- Dakganj

District- Banda Logging Depth- 120 mt

Drilling Depth- 120 mt Water Level- 6 mt

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-6	Dry Sand	
3	6-15	dry loam	
4	15-33	Medium Sand	poor
5	33-38	dry loam	
6	38-65	Medium Sand	medium
7	65-75	dry loam	
8	75-95	Medium Sand	poor
9	95-98	dry loam	
10	98-112	Medium Sand + silt	poor
11	112-120	dry loam	
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

[Signature]
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
Construction of Recharge Well, Reconditioning of Tubewells, Ground Water Investigations