



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
 Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date: 8-1-23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- PNC Badaun Bhagwati bore well
 Village - Alidapur Samastpur Block- Islam Nagar
 District- Badaun Logging Depth- 140 mt
 Drilling Depth- 140 mt Water Level- 18 mt

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface soil	
2	5-18	Dry Sand	
3	18-45	Medium Sand	Sand
4	45-50	clay kerker	
5	50-55	Medium Sand	Sand
6	55-67	clay kerker	
7	67-78	Medium Sand	Sand
8	78-84	clay kerker	
9	84-96	Medium Sand	Sand
10	96-110	clay kerker	
11	110-120	Medium Sand	Sand
12	120-140	clay kerker	
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

A. Far
 Bhagwati Borewell

S. Singh
 Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.