



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9781163000, 9794825420, Email : gwsc_agra@yahoo.com

No.

Date. 25.1.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES


Name Of Agency- PNC Badain Bhagwati Dore well Ujhan

Village - Ghatka Block- Wazirganj

District- Badain Logging Depth- 120 mts

Drilling Depth- 120 mts Water Level- 18 mts

| S.No | Depth in Mtr. | Lithology | Expected Water Quality |
|------|---------------|-----------------|------------------------|
| 1 | 0 - 5 | Surface Soil | |
| 2 | 5 - 15 | clay kankar | |
| 3 | 15 - 20 | Dry Sand | |
| 4 | 20 - 25 | fine sand | Med + Good |
| 5 | 25 - 33 | clay kankar | |
| 6 | 33 - 45 | Medium Sand | Med + Good |
| 7 | 45 - 52 | clay kankar | |
| 8 | 52 - 55 | Medium Sand | Med + Good |
| 9 | 55 - 65 | clay kankar | |
| 10 | 65 - 88 | Medium Sand | Med + Good |
| 11 | 88 - 92 | clay kankar | |
| 12 | 92 - 98 | kankar with bed | Med + Good |
| 13 | 98 - 120 | clay kankar | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |
| 21 | | | |
| 22 | | | |
| 23 | | | |



Expected Water Bearing Zone

For Ground Water Survey Consultancy

[Signature]
01/02/2023

[Signature]
Geophysicist

Specializations in

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations