

GSTIN : 09AEOPG8965L2ZJ



# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282008

Mob. : 9761163000, 9794625420, Email : gwsc\_agra@yahoo.com

Ref No. ....


Date 4.3.22

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

### DETAIL OF WATER BEARING ZONES

Name Of Agency - P.V.C. Infrastructure (Chajwal Tube well)  
 Village - Hada Kotey Block - Sahaswan  
 District - Badliu Logging Depth - 115 mt  
 Drilling Depth - 110 mt Water Level - 3 mt

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface soil	
2	5-7	clay	
3	7-15	fine sand	
4	15-18	clay layer	
5	18-35	medium sand	medium
6	35-48	clay layer	
7	48-55	medium sand	medium
8	55-61	clay layer	
9	61-70	medium sand	medium
10	70-77	clay layer	
11	77-95	fine & med sand	good
12	95-98	fine sand	
13	98-105	fine & med sand	medium
14	105-110	clay	
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

For  
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,  
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.