




112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006  
 Mob : 9761163000, 9794625420, Email : gwsc\_agra@yahoo.com

Date: 26-04-20

**GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT**  
**DETAIL OF WATER BEARING ZONES**

Name Of Agency: .....  
 Village: Sakhawan .....  
 District: Badayun .....  
 Logging Depth: 120 mtr .....  
 Water Level: 15 mtr .....  
 Filling Depth: 120 mtr .....

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 15	Dark sand	
3	15 - 26	Fine Sand	
4	26 - 30	Clay KanKar	
5	30 - 50 *	Fine to Med. Sand	Good
6	50 - 59	Clay	
7	59 - 71 *	Medium Sand	Good
8	71 - 73	Clay KanKar	
9	73 - 80 *	Medium Sand	Good
10	80 - 87	KanKar	
11	87 - 117 *	Fine to Medium Sand	Good
12	117 - 120	Clay KanKar	
13			
14			
15			
16			
17			
18			
19			



For Ground Water Survey Consultancy

Expected Water Bearing Zone

51