

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

**GEO-PHYSICAL WELL
ELECTROLOGGING REPORT**

Ref No:- N-722

Date:- 12-01-2023

NAME OF SITE

Gram Panchayat- Tehra

BLOCK- Ujhani

DISTT- Badaun

NAME OF AGENCY

M/s PNC-SPML-JV
Badaun



GROUND WATER SURVEY CONSULTANCY


Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO 9001:2015

Ground Water Survey Consultancy
Agra



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- TEHRA, BLOCK- UJHANI, DISTT.- BADAUN
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 110 mtrs. depth. and Logged depth 110 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Badaun.

On the request of M/S PNC-SPML-JV, Badaun. a Geophysical well Logging is conduct at above bore hole using IGIS Well Logger on 12.Jan.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 18	13	Dry sand	
3.	18 - 33	15	Fine to Medium sand	
4.	33 - 35	2	Clay kankar	
5.	35 - 45*	10	Medium sand	Good
6.	45 - 60	15	Clay kankar	
7.	60 - 68*	8	Medium sand	Good
8.	68 - 77	9	Clay kankar	
9.	77 - 82*	5	Medium sand	Good
10.	82 - 98	16	Clay kankar	
11.	98 - 102	4	Fine sand	Good
12.	102 - 110	8	Clay kankar	



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Good.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

B

Rho a
 N16 (SN)
 N60(LN)
 LAI

Logging of Test
 Bed: Upper Duff
 Bedrock
 Log 106/04
 12 Jan 2015
 M 52
 UTM: 500000, 4500000

E

SP (mV)

