REPORT ON GEOPHYSICAL WELL LOGGING

GRAM PANCHAYAT- BEHTA PATHAK, BLOCK- BISAULI DISTT.- BADAUN UNDER JAL JIVAN MISSION

Introduction:

A Deep bore hole was drilled 124 mtrs. depth. and Logged depth 121 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Badaun.

On the request of M/S PNC-SPML-JV, Badaun. a Geophysical well Logging is conduct at above bore hole using IGIS Well Logger on 12.Oct.2022.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral.

Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

| S.No. | Depth range(m) | Thickness(m) | Lithology | Expected Water Quality |
|-------|-------------------|--------------|---------------------|------------------------|
| 1. | 0 - 5 | 5 | Surface soil | |
| 2. | 5 - 16 | 11 | Dry sand | |
| 3. | 16 - 25 | 9 | Sandy clay | |
| 4. | 25 - 34 | 9 | Fine to Medium sand | Good |
| 5. | 34 - 40 | 6 | Clay kankar | |
| 6. | 40 - 55* | 15 | Medium sand | Good |
| 7. | 55 - 58 | 3 | Clay kankar | |
| 8. | 58 - 62 | 4 | Sand & kankar | Good |
| 9. | 62 - 65 | 3 | Clay kankar | |
| 10. | 65 - 77* | 12 | Medium sand | Good |
| 11. | 77 - 90 | 13 | Clay kankar | |
| 12. | 90 - 96 | 6 | Fine sand | Good |
| 13. | 96 - 104 | 8 | Clay kankar | |
| 14. | 104 - 111* | 7 | Fine to Medium sand | Good |
| 15. | 111 - 117 | 6 | Clay kankar | |
| 16. | 117 - 121 | 4 | Sandy clay | |



Conclusions and Recommendations :-

- 1. The Lithology broadly tallies with that of drill cutting strata chart.
- The zones marked with asterisk (*) appear to be aquifer zones for possible Development of tube well.
- The Quality of water is expected Good.
- It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
- All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist

Ground Water Survey Consultancy

S K N 16(SN) Ohm m -03 - 80-8 ᅙ-3-8-3-8-ጜ**t**-**:**-8-Ground 쑹-Depth(m) Nancy -6 3-8-8-8-%-8-<u>.</u> 5. 3-