

**GROUND WATER SURVEY CONSULTANCY**

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

**ELECTROLOGGING REPORT  
GEO-PHYSICAL WELL**

Ref No:- A-2184 Date:- 08-11-2023

**GRAM PANCHAYAT- Tak Parauli      BLOCK- Islamnagar      DISTT- Badanu**

**NAME OF SITE**

**NAME OF AGENCY**

**M/s PNC-SPML-JV**

**Badanu**



**GROUND WATER SURVEY CONSULTANCY**

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.  
112 A-Sheer Nagar Colony, Firuzabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwscc\_agra@yahoo.com

Ground Water Survey Consultancy  
Agra



S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 15	10	Dry sand	
3.	15 - 30	15	Clay Kanakar	
4.	30 - 53*	23	Medium sand	Medium
5.	53 - 60	7	Clay Kanakar	
6.	60 - 65*	5	Medium sand	Medium
7.	65 - 70	5	Clay Kanakar	
8.	70 - 86*	16	Medium sand	Medium
9.	86 - 91	5	Clay Kanakar	
10.	91 - 95*	4	Medium sand	Medium
11.	95 - 100	5	Clay Kanakar	
12.	100 - 103	3	Fine sand	
13.	103 - 130	27	Sandy clay	Medium

of Strata Chart prepared from drill cuttings are given in the following table:-

Details of major aquifer formations explored from logging of bore hole combined with the study

Logging Para meters - Self potential, shot normal (N-16), Long Normal (N-64), Laterall.

Logging in the above bore hole using GIS Well Logger on 08.Nov.2023.

On the request of M/S PNC-SML-JV, Badanu, a Geophysical well

at above site, Was drilled by M/S PNC-SML-JV, Badanu.

A Deep bore hole was drilled 130 mtrs. depth, and Logged depth 130 mtrs.

#### Introduction:

### JAL JIVAN MISSION

#### UNDER

GRAM PANCHAYAT- TARK PARRAULI, BLOCK- ISLAMNAGAR, DISTT- BADANU

### REPORT ON GEOPHYSICAL WELL LOGGING AT

## Ground Water Survey Consultancy



Geophysicist

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (\*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

**Conclusions and Recommendations :-**

