

GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL ELECTROLOGGING REPORT

Ref No:-A -1442

Date:- 19-08-2023

NAME OF SITE

GRAM PANCHAYAT- Kantaur

BLOCK- Kasganj

DISTT- Kasganj

NAME OF AGENCY

M/s PNC-SPML-JV
Kasganj



GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy
Agra



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- KANTAUR, BLOCK- KASGANJ, DISTT- KASGANJ
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 110 mtrs. depth. and Logged depth 110 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Kasganj.

On the request of M/S PNC-SPML-JV, Kasganj. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 19.Aug.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

Mud Resistivity = 14.40 Ohms.

Drilling Water Resistivity = 15.20 Ohms.

Approx Water Level = 24 Mtr.


S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 15	10	Dry sand	
3.	15 - 20	5	Fine sand	
4.	20 - 27	7	Clay kankar	
5.	27 - 32*	5	Medium sand	Medium
6.	32 - 46	14	Clay kankar	
7.	46 - 49*	4	Medium sand	Medium
8.	49 - 56	7	Clay kankar	
9.	56 - 67*	11	Medium sand	Medium
10.	67 - 85	18	Clay kankar	
11.	85 - 90*	5	Fine to medium sand	Medium
12.	90 - 110	20	Clay kankar	



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

Rho a
N16 (SN)
NS4(LN)
LAT

Logging Details:
Logging Software: Res
Logging Date: 19 Aug 2023
Log ID: 19082023
21 23
User: Suresh JAS

Logger S No: IGIS/5/02/22-23

SP (m V)

DMP1.2

Logger Owned by

GROUND WATER SURVEY CONSULTANCY
AGRA, UP, INDIA

