

# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

## GEO-PHYSICAL WELL ELECTOLOGGING REPORT

Ref No:-A-1377

Date:- 14-08-2023

### NAME OF SITE

GRAM PANCHAYAT- Mahawar

BLOCK- Kasganj

DISTT- Kasganj

### NAME OF AGENCY

M/s PNC-SPML-JV  
Kasganj



## GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc\_agra@yahoo.com

**ISO ; 9001 : 2015**

Ground Water Survey Consultancy



# REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- MAHAWAR, BLOCK- KASGANJ,  
DISTT- KASGANJ

UNDER  
JAL JIVAN MISSION

## Introduction :

A Deep bore hole was drilled 100 mtrs. depth. and Logged depth 100 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Kasganj.

On the request of M/S PNC-SPML-JV, Kasganj. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 14.Aug.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

Mud Resistivity = 15.39 Ohms.

Drilling Water Resistivity = 16.74 Ohms.

Approx Water Level = 6 Mtr.

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 14	9	Medium sand	
3.	14 - 25	11	Clay kankar	
4.	25 - 33	8	Medium sand	Medium
5.	33 - 47	14	Clay kankar	
6.	47 - 62*	15	Medium sand & kankar	Medium
7.	62 - 100	38	Clay kankar	

Ground Water Survey Consultancy  


**Conclusions and Recommendations :-**

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (\*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

**Geophysicist**



**Ground Water Survey Consultancy**



Rho a  
 NTIS (SN)  
 NS4(LIN)  
 LA1

Logging Details:  
 Logging of Murren 2003  
 01/01/03 to 31/03/03  
 12 Aug 2003  
 14.12  
 2003

Logger S No: IG/S/03/21-22

Logger Model: SP (m V)

DMP/L-2  
 Logger Owned by:  
 GROUND WATER SURVEY CONSULTANCY - AGRA INDIA

