

GROUND WATER SURVEY CONSULTANCY

WATER ANALYSIS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL ELECTROLOGGING REPORT

Ref No: A-1332

Date:- 13-08-2023

NAME OF SITE

GRAM PANCHAYAT- Malikpur Chakrapur
DISTT- Kasganj

BLOCK- Soron

NAME OF AGENCY

M/s PNC-SPML-JV
Kasganj



GROUND WATER SURVEY CONSULTANCY

Electr. Well Logging, Geophysical Resistivity Survey, Ground Water Investigations,
112, 1st Floor, Near Colony, Fire Brigade Road, Agra-202006

PH: 402260822, 474627221, 474612500, Email: gws_agra@yahoo.com

ISO : 9001 : 2015

Ground Water Survey Consultancy



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- MALIKPUR CHAKOOPUR, BLOCK- SORON, DISTT- KASGANJ
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 110 mtrs. depth. and Logged depth 110 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Kasganj.

On the request of M/S PNC-SPML-JV, Kasganj. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 13.Aug.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

Mud Resistivity = 14.41 Ohms.

Drilling Water Resistivity = 15.20 Ohms.

Approx Water Level = 6 Mtr.

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 8	3	Clay kankar	
3.	8 - 26	18	Medium sand	Medium
4.	26 - 43	17	Clay kankar	
5.	43 - 68*	25	Medium sand	Medium
6.	68 - 72	4	Clay kankar	
7.	72 - 77*	5	Fine to medium sand	Medium
8.	77 - 85	8	Clay kankar	
9.	85 - 97*	12	Fine to medium sand	Medium
10.	97 - 110	13	Clay kankar	



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

Rho a
N 16(SW)
N 64 (LN)
LAT

Location:
Logging V. Name:
Character: Rock - Sand
Dip: - (angle)
Log No.:
UP LOGS/NO/24
Date:
13 Aug 2023
Time:
14:23
Operator:
User: G. S. J.
VBI Data:

Logger S. No.:
IGIS/S/02/22-23

Logger Model:
SP

DMPL-2

Logger Owned by:
GROUND WATER
SURVEY
CONSULTANCY
AGRA, UP, INDIA

