

SUPREME WATER SOURCES. TUBEWELL ENGINEERS & CONSULTANTS

Regd. Office : CHO. Road, Ekta Colony, Opp. Bhabat Petrol Pump, Rajpura (PB.) SERVICE : DigitalElectronic Well Logger upto 600 m

Resistivity Survey upto 1000 m Survey for Rain Harvesting Wells.

Mobile :8728000086, 9878605686, 75080-00047 E-mail: supremewater8886@gmail.com

BOREHOLE DRILLED AT SITE GP BAIRMABAD GADI BLOCK NEHTOR, DISTT. BIJNOR (UP)

Drilled Depth :- 160 m Logg Depth :- 160 m

Water Level :- 30 m (Approx.)
Date :-18-04-2024

Name of Agency:- M/s L C Infratech.

OBSERVED

The following granular zones have been observed beyond the static ground water level with the help of Advanced Electronic Geophysical Logger

Depth Range In Mtrs. (B.G.L.)		Length (Mtrs.)	Nature of Samples	Expected Water Quality
0	6	6	Surface Clay with top Soil	
6	24	18	Fine Medium Sand	
24	30	6	Clay	
30	43	13	Fine Medium Sand	
43	45	2	Clay	
45	125	80	Core Sand	Good
125	131	6	Clay	
131	137	6	Fine Sand	Good
137	141	4	Clay	
141	144	3	Fine Sand	Good
144	148	4	Clay	
148	153	5	Fine Medium Sand	Good
153	156	3	Clay	
156	160	4	Fine Sand	Fair

For Supreme Water Sources

Amanded

Prop.