

GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL ELECTROLOGGING REPORT

Ref No:-A-2267

Date:- 29-11-2023

NAME OF SITE

GRAM PANCHAYAT- Gangsara

BLOCK- Sidhpura

DISTT- Kasganj

NAME OF AGENCY

M/s PNC-SPML-JV
Kasganj



GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- GANGSARA, BLOCK- SIDHPURA, DISTT- KASGANJ UNDER JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 100 mtrs. depth. and Logged depth 100 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Kasganj.

On the request of M/S PNC-SPML-JV, Kasganj. a Geophysical well Logging is conduct at above bore hole using IGIS Well Logger on 29.Nov.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

Mud Resistivity = 16.33 Ohms.

Drilling Water Resistivity = 17.09 Ohms.

Approx Water Level = 6 Mtr.

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 6	1	Clay kankar	
3.	6 - 14	8	Medium sand	Medium
4.	14 - 40	26	Clay kankar	
5.	40 - 59*	19	Medium sand	Medium
6.	59 - 65	6	Clay kankar	
7.	65 - 70*	5	Medium sand	Medium
8.	70 - 80	10	Clay kankar	
9.	80 - 97*	17	Medium sand	Medium
10.	97 - 100	3	Clay kankar	

Ground Water Survey Consultancy



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

Box 8

N16 (SN)
N64(LN)
LAT

Logging Details:

Logging & preparation done
at the site of the well
on 22 Nov 2011
4:31
Station name: Agra

Logger S No:

IGIS/S/03/21-22

Box

SP (mV)

Logger Model:

DMPL-2

Logger Owned by:

GROUND WATER
SURVEY
CONSULTANCY
- AGRA INDIA

