



1.Executive Engineer,C.D.(Rural),U.P. Jai Nigam, Gonda
2.M/S Vishwanath Projects Limited,Bahrach

CC:

Abhishek Kumar
Geophysicist

For Mining Associates Pvt. Ltd

NOTE:- 1. ALL zones have intermixed with thin band of kankar

Sl. No.	Depth		Inferred lithology	Remark(Quality of Aquifer Water)
	From (m)	To (m)		
1	0	10	Top Soil	
2	10	37	Medium grain sand	Good
3	37	41.5	Clay	
4	41.5	63	Medium grain sand	Good
5	63	66	fine sediment	
6	66	70	Medium to fine grain sand	Good
7	70	72	fine sediment	
8	72	162	Medium to fine grain sand	Good
9	162	166	Clay with sand	
10	166	173.5	Medium to fine grain sand	Good
11	173.5	182.5	Clay with sand	
12	182.5	293	Medium to fine grain sand & kankar	Good
13	293	296	Clay	
14	296	300	Medium grain sand	Good

<p>NOTE:- These values are only indicative. The thin clay or sand layer does not reveal its actual resistivity value zones. The depth zones with less resistivity and relatively high Natural Gamma radioactivity values are referred as Clay zones. CLAY: Zones. The depth zones with high resistivity and relatively low Natural Gamma radioactivity values are referred as Aquifer zones. AQUIFER:</p>			
SITE:	DHARMAPUR	DATE OF LOGGING:	01.02.2024
BLOCK:	MIHINPURWA	DRILLING DEPTH:	305.00 M
STATE:	UTTAR PRADESH	LOGGING DEPTH:	300.00M
ENG:	ASHOK KUMAR	LOGGING COMPANY:	Mining Associates Pvt. Ltd
Rm	11.9 ohm.m	Rw	13.5 ohm.m
DISTRIC	BAHRAICH		

GEOPHYSICAL DIGITAL LOGGING REPORT

MINING ASSOCIATES PVT. LTD.



MAPL