

# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

## GEO-PHYSICAL WELL ELECTROLOGGING REPORT

Ref No:-A-1836

Date:- 10-10-2023

### NAME OF SITE

GRAM PANCHAYAT- Dandra

BLOCK- Dahagawan

DISTT- Badaun

### NAME OF AGENCY

M/s PNC-SPML-JV

Badaun



## GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.


112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc\_agra@yahoo.com

**ISO ; 9001 : 2015**

Ground Water Survey Consultancy

Agra



# REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- DANDRA, BLOCK- DAHAGAWAN, DISTT- BADAUN  
UNDER  
JAL JIVAN MISSION

## Introduction :

A Deep bore hole was drilled 130 mtrs. depth. and Logged depth 130 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Badaun.

On the request of M/S PNC-SPML-JV, Badaun. a Geophysical well Logging is conduct at above bore hole using IGIS Well Logger on 10.Oct.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 16	11	Clay kankar	
3.	16 - 30	14	Medium sand	Medium
4.	30 - 45	15	Clay kankar	
5.	45 - 54*	9	Medium sand	Medium
6.	54 - 65	11	Clay kankar	
7.	65 - 70*	5	Medium sand	Medium
8.	70 - 75	5	Clay kankar	
9.	75 - 95*	20	Medium sand	Medium
10.	95 - 103	8	Clay kankar	
11.	103 - 120*	17	Medium sand	Medium
12.	120 - 130	10	Clay kankar	


Ground Water Survey Consultancy



**Conclusions and Recommendations :-**

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (\*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

**Geophysicist**



**Ground Water Survey Consultancy**

Rho a  
 N16 (SN)  
 N64(LN)  
 LAT  
 Logging Details:  
 Logging GP Danda Stock  
 Charanjan Ditt Sudaan  
 UP ICGS/NGUP  
 10 Oct 2023  
 1239  
 Utkarsh Gupta (AG)

Logger S. No:  
 IGS/5/01/21-22

SP (m V)  
 Logger Model:  
 DMPL-2  
 Logger Owned by:  
 GROUND WATER  
 SURVEY  
 CONSULTANCY  
 AGRA, UP, India

