

GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL ELECTOLOGGING REPORT

Ref No:-A-1973

Date:- 21-10-2023

NAME OF SITE

GRAM PANCHAYAT- Haivatpur

BLOCK- Ambiyapur

DISTT- Badaun

NAME OF AGENCY

M/s PNC-SPML-JV
Badaun



GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- HAIVATPUR, BLOCK- AMBIYAPUR,
DISTT- BADAUN
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 135 mtrs. depth. and Logged depth 130 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Badaun.

On the request of M/S PNC-SPML-JV, Badaun. a Geophysical well Logging is conduct at above bore hole using IGIS Well Logger on 21.Oct.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

| S.No. | Depth range(m) | Thickness(m) | Lithology | Expected Water Quality |
|-------|----------------|--------------|----------------------|------------------------|
| 1. | 0 - 5 | 5 | Surface soil | |
| 2. | 5 - 15 | 10 | Dry sand | |
| 3. | 15 - 30 | 15 | Clay kankar | |
| 4. | 30 - 42 | 12 | Medium sand & kankar | Medium |
| 5. | 42 - 46 | 4 | Clay kankar | |
| 6. | 46 - 51 | 5 | Medium sand | Medium |
| 7. | 51 - 61 | 10 | Clay kankar | |
| 8. | 61 - 79* | 18 | Medium sand | Medium |
| 9. | 79 - 81 | 2 | Clay kankar | |
| 10. | 81 - 91* | 10 | Medium sand | Medium |
| 11. | 91 - 102 | 11 | Clay kankar | |
| 12. | 102 - 115* | 13 | Medium sand | Medium |
| 13. | 115 - 130 | 15 | Clay kankar | |


Ground Water Survey Consultancy



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

Rho a
 N16 (SN)
 N64(LN)
 LAT
 Logging Details:
 Logging GP: H/Vistour, Book
 Ambedkar Crst Budhan
 DOWN LOGS/HG-Dem
 21 Oct 2023
 11.41
 Usharan G-ara (AG)

Logger S1 No:
 IGS/S/O1/21-22

Logger Model:
 DMPL-2

Logger Owned by:
 GROUND WATER
 SURVEY
 CONSULTANCY
 AGRA, UP, India

