

# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

## GEO-PHYSICAL WELL ELECTROLOGGING REPORT

Ref No:-B-1619

Date:- 11-09-2023

### NAME OF SITE

GRAM PANCHAYAT- Dikauli

BLOCK- Gilaula

DISTT- Shravasti

### NAME OF AGENCY

M/s Vishwanath Project Limited  
Shravasti



## GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc\_agra@yahoo.com

**ISO ; 9001 : 2015**

Ground Water Survey Consultancy



# REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- DIKAULI, BLOCK- GILAULA, DISTT- SHRAVASTI  
UNDER  
JAL JIVAN MISSION

## Introduction :

A Deep bore hole was drilled 165 mtrs. depth. and Logged depth 165 mtrs. at above site. Was drilled by M/s Vishwanath Project Limited, Shravasti.

On the request of M/s Vishwanath Project Limited, Shravasti. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 11.Sep.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major Aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

Mud Resistivity = 24.58 Ohms.

Drilling Water Resistivity = 25.65 Ohms.

Approx Water Level = 6 Mtr

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 8	3	Clay	
3.	8 - 16	8	Fine to Medium sand	
4.	16 - 23	7	Clay kankar	
5.	23 - 25	2	Fine sand	
6.	25 - 36	11	Clay kankar	
7.	36 - 46	10	Medium sand	Good
8.	46 - 65	19	Clay kankar	
9.	65 - 101*	36	Medium sand	Good
10.	101 - 111	10	Clay kankar	
11.	111 - 125*	14	Medium sand	Good
12.	125 - 135	10	Clay kankar	
13.	135 - 154*	19	Medium sand	Good
14.	154 - 165	11	Clay kankar	

Ground Water Survey Consultancy



**Conclusions and Recommendations :-**

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (\*) appear to be aquifer zones for possible Development of tube well.
3. The Quality of water is expected Good.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

**Geophysicist**



**Ground Water Survey Consultancy**



Rho a

- N16 (SN)
- NS4(LN)
- LAT

Location:  
 Logging V/Chal. Area  
 Station No. 100000  
 Log No. 100000  
 Date 11 Sep 2022  
 Time 11:55  
 Client: Unani Qada (UQ)  
 Ref. Station

Logger S No: KGS/S/01/21-22

Logger Model: SP

Logger Name: DMPL-2

Logger Created by:

GROUND WATER SURVEY CONSULTANCY AGRA, UP, India

