

SUPREME WATER SOURCES. TUBEWELL ENGINEERS & CONSULTANTS

Regd. Office : CHO. Road, Ekta Colony, Opp. Bhabat Petrol Pump, Rajpura (PB.)

SERVICE: DigitalElectronic Well Logger upto 600 m

Resistivity Survey upto 1000 m Survey for Rain Harvesting Wells.

Mobile :8728000086, 9878605686, 75080-00047 E-mail: supremewater8886@gmail.com

BOREHOLE DRILLED AT SITE NAWALA DISTT.MUZZAFARNAGAR

Drilled Depth: - 150 m

Logg Depth :- 150 m

Water Level :- 7 m (Approx.)

Date :- 16/04/2024

OBSERVED

The following granular zones have been observed beyond the static ground water level with the help of Advanced Electronic Geophysical Logger

Depth Range In Mtrs.		Length	Nature Of Samples	Expected
(B.G.L.)		(Mtrs.)		Water Quality
0.00	6.00	6.00	Clay	
6.00	30.00	24.00	Fine Sand	
30.00	32.00	2.00	Clay	
32.00	53.00	21.00	Fine Medium Sand	
53.00	94.13	41.13	Clay	
94.13	111.73	17.60	Medium Sand	Good
111.73	114.43	2.70	Clay	
114.43	128.90	14.47	Medium Sand	Good
128.90	150.00	21.10	Clay	

For Supreme Water Sources