M/s ANIL KUMAR

KDA Colony, Daheli Sujanpur, Shyam Nagar Kanpur 6206697773 rakesh@akgroupindia.co.in

Geophysical Well Logging Report

Ref No -AK/LOG/119

Date -22/11/23

Site Location

: - SUPA

Block & District

: -Teliyani, Fatehpur

Logged Depth

: - 95 MBGL

Date of Logging

: - 21.11.2023

Types of Log

: - S.P& N16, N-64

LATLogger used

: - IGIS

Name of Agency

: GAYATRI-RAMKY

Rm - 22.60 Ωm

Rw - 19.11 Ωm

The following permeable granular zones have been deciphered with

thehelp of Electrical Logger

Sr NO	DepthRange From M.B.G.L	Depth Range M.B.G.L.	Thickness Mtr.	Type of Strata
04	24	39	15	Coarse Sand
01	65	79	14	Fine to Medium Sand

Remarks :-

1. Water quality is fresh in all the above zones

II. Good clays in depth intervals 48-55 & 81-84 mbgl.

III. Housing down to 50 m and Bail plug in 81-84 m depth range preferably one three metre slot in 36-39 m bgl.

B.B. Trivedi Chief Consultant Former Senior Scientist, Ministry of Water Resources, Govt. of India