

GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL ELECTOLOGGING REPORT

A-210
Ref No:-P- 106

Date:- 12-04-2023

NAME OF SITE

GRAM PANCHAYAT- Najamadpur Borna BLOCK- Lodha DISTT- Aligarh

NAME OF AGENCY

M/s Kalpataru Power Transmission Limited
Aligarh



GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 ; 2015

Ground Water Survey Consultancy
Agra



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- NAJAMADPUR BORNA, BLOCK- LODHA, DISTT- ALIGARH
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 120 mtrs. depth. and Logged depth 115 mtrs. at above site. Was drilled by M/s Kalpataru Power Transmission limited, Aligarh.

On the request of M/s Kalpataru Power Transmission limited, Aligarh. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 12.April.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major Aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-


Mud Resistivity = 15.20 Ohms.

Drilling Water Resistivity = 16.31 Ohms.

Approx Water Level = 12 Mtr.

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 15	10	Dry sand	
3.	15 - 22	7	Clay	
4.	22 - 30	8	Fine to Medium sand	Medium
5.	30 - 53*	23	Medium sand	Medium
6.	53 - 58	5	Clay kankar	
7.	58 - 66*	8	Medium sand	Med to Marginally
8.	66 - 75	9	Clay kankar	
9.	75 - 83	8	Medium sand	Marginally saline
10.	83 - 115	32	Clay kankar	


Ground Water Survey Consultancy



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible Development of tube well.
3. The Quality of water is expected Medium to Marginally saline.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

Rio a
 N16 (SN)
 N64(LN)
 LAT
 Logging Details
 Log No: 116-11
 Date: 12 Apr 2013
 Time: 12:08
 User: vishu
 Logger S No: IGIS/S/01/10-11
 Logger Model: SP (m V)
 DMAP L-2
 Logger Owned by:
 GROUND WATER
 SURVEY
 CONSULTANCY
 - AGRA INDIA

