



SUPREME WATER SOURCES.
TUBEWELL ENGINEERS
& CONSULTANTS

SUPREME WATER SOURCES.

TUBEWELL ENGINEERS & CONSULTANTS

Regd. Office: CHD. Road, Ekta Colony, Opp. Bhabat Petrol Pump, Rajpura
(PB.) SERVICE : Digital Electronic Well Logger upto 600 m
Resistivity Survey upto 1000 m Survey for Rain Harvesting Wells.
Mobile :8728000086, 9878605686, 75080-00047 E-mail: supremewater8886@gmail.com

BOREHOLE DRILLED AT SITE VILL. RUKANPUR,
BLOCK CHARTHAWAL, DISTT. MUZAFFARNAGAR (UP)

Drilled Depth :- 140 m
Logg Depth :- 140 m
Water Level :- 10 m (Approx.)
Date :- 04/10/2023

OBSERVED

The following granular zones have been observed beyond the static ground water level with the help of Advanced Electronic Geophysical Logger

Depth Range In Mtrs. (B.G.L.)		Length (Mtrs.)	Nature Of Samples	Expected Water Quality
0.00	2.00	2.00	Surfece Clay with top Soil	
2.00	7.00	5.00	Fine Medium Sand	
7.00	19.00	12.00	Clay	
19.00	29.00	10.00	Fine Medium Sand	
29.00	42.50	13.50	Clay	
42.50	45.00	2.50	Medium Sand	Good
45.00	52.50	7.50	Clay	
52.50	60.00	7.50	Medium Sand	Good
60.00	65.00	5.00	Clay	
65.00	84.00	19.00	Medium Sand	Good
84.00	89.00	5.00	Clay	
89.00	96.00	7.00	Medium Sand	Good
96.00	100.00	4.00	Clay	
100.00	134.50	34.50	Medium Sand	Good
134.50	140.00	5.50	Clay	

For Supreme Water Sources

Amanolek
Prop.