

REPORT ON GEO-PHYSICAL RESISTIVITY LOGGING OF BOREHOLE

A deep borehole was drilled by working agency M/s. GVPR ENGINEERING LIMITED as a part of their scope of work of development of Tubewell under Jal Jeevan Mission Project of SWSM, MTL conducted a Geophysical Continuous logging in the above borehole.

Village Name	Modinagar
Block	Haseran
District	Kannauj, U.P.
Logged Depth	195 Mtr BGL
Type of Log	Continuous well logger (SP, N16 (SN), N64 (LN) & LAT)
Machine Used	IGIS
Logging Date	06.05.2023

The following aquifer zones have been deciphered with the help of logging machine.

Sr. No.	Depth Range (mtr BGL)	Thickness (mtr)	Expected Quality
1	37 – 40	3	Good
2	46 – 56	4	Good
3	81 – 90	9	Good to moderate

~~Rw – 14.6 Ohm mtr and Rm – 13.8 Ohm mtr~~

Note: Sr no 1 is Find Sand and Below 100 MBGL the quality of the formation water is marginal to saline till log depth.

- Logging performed as per SWSM guidelines.
- Groundwater quality interpreted by firm as per their logger calibration

For Geo-Technical Consultant,



Authorised Signatory

G.Sh
00/05/23



GEO - TECHNICAL
CONSULTANT

GEO – TECHNICAL CONSULTANT

(Division of MACHTECH)

Plot no. 61 Vikaskung, Near Tower, Dibiyapur – 206244, District – Auraiya, Uttar
Pradesh (India)

E-mail: machtechtools55@gmail.com , Mobile Number :- 9265018387



