



SUPREME WATER SOURCES.

TUBEWELL ENGINEERS & CONSULTANTS

Regd. Office: CHD. Road, Ekta Colony, Opp. Bhabat Petrol Pump, Rajpura (PB.)

SERVICE : Digital Electronic Well Logger upto 600 m

Resistivity Survey upto 1000 m Survey for Rain Harvesting Wells.

Mobile :8728000086, 9878605686, 75080-00047 E-mail: supremewater8886@gmail.com

SUPREME WATER SOURCES.

TUBEWELL ENGINEERS

& CONSULTANTS

BOREHOLE DRILLED AT SITE VILL. SLAMPUR, BLOCK MUZAFFARNAGAR,
DISTT. MUZAFFARNAGAR (UP)

Drilled Depth :- 140 m

Logg Depth :- 140 m

Water Level :- 15 m (Approx.)

Date :- 03/09/2023

OBSERVED

The following granular zones have been observed beyond the static ground water level with the help of Advanced Electronic Geophysical Logger

| Depth Range In Mtrs. (B.G.L.) | | Length (Mtrs.) | Nature Of Samples |
|----------------------------------|--------|-------------------|--------------------|
| 0.00 | 1.00 | 1.00 | Clay |
| 1.00 | 27.50 | 26.50 | Fine Medium Sand |
| 27.50 | 35.00 | 7.50 | Clay |
| 35.00 | 42.00 | 7.00 | Fine Medium Sand |
| 42.00 | 47.00 | 5.00 | Clay |
| 47.00 | 51.00 | 4.00 | Medium Sand |
| 51.00 | 56.00 | 5.00 | Clay |
| 56.00 | 69.50 | 13.50 | Medium Sand |
| 69.50 | 72.50 | 3.00 | Clay |
| 72.50 | 84.00 | 11.50 | Medium Sand |
| 84.00 | 87.00 | 3.00 | Clay |
| 87.00 | 90.00 | 3.00 | Medium Sand |
| 90.00 | 93.00 | 3.00 | Clay |
| 93.00 | 102.50 | 9.50 | Medium Sand |
| 102.50 | 106.50 | 4.00 | Sandy Clay Mix |
| 106.50 | 133.00 | 26.50 | Medium Coarse Sand |
| 133.00 | 140.00 | 7.00 | Clay |

For Supreme Water Sources

Amandeep
Prop.