

SUPREME WATER SOURCES. TUBEWELL ENGINEERS & CONSULTANTS

Regd. Office: CHO. Road, Ekta Colony, Opp. Bhabat Petrol Pump, Rajpura (PB.) SERVICE: DigitalElectronic Well Logger upto 600 m Resistivity Survey upto 1000 m Survey for Rain Harvesting Wells. Mobile:8728000086, 9878605686, 75080-00047 E-mail: supremewater8886@gmail.com

BOREHOLE DRILLED AT SITE GP KHEDKI HEMRAJ BLOCK DEVMAL, DISTT. BIJNOR (UP)

Drilled Depth :- 155 m Logg Depth :- 155 m

Water Level :- 1 m (Approx.)
Date :-04-05-2024

Name of Agency:- M/s L C Infratech.

OBSERVED

The following granular zones have been observed beyond the static ground water level with the help of Advanced Electronic Geophysical Logger

Depth Range In Mtrs. (B.G.L.)		Length (Mtrs.)	Nature of Samples	Expected Water Quality
0	1	1	Surface Clay with top Soil	
1	58	57	Core Sand	
58	75	17	Fine Medium Sand	
75	98	23	Medium Core Sand	Good
98	110	12	Fine Medium Sand	
110	127	17	Core Sand	Good
127	133	6	Fine Medium Sand	
133	155	22	Core Sand	Good

For Supreme Water Sources