

SUPREME WATER SOURCES. TUBEWELL ENGINEERS & CONSULTANTS

Regd. Office : CHO. Road, Ekta Colony, Opp. Bhabat Petrol Pump, Rajpura (PB.)

SERVICE: DigitalElectronic Well Logger upto 600 m

Resistivity Survey upto 1000 m Survey for Rain Harvesting Wells.

Mobile: 8728000086, 9878605686, 75080-00047 E-mail: supremewater8886@gmail.com

BOREHOLE DRILLED AT SITE GP NATHADOI BLOCK ALHEPUR, DISTT. BIJNOR (UP)

Drilled Depth: - 160 m

Logg Depth :- 155 m

Water Level :- 20 m

Date :- 08/11/2023

Name of Agency:- M/S L C INFRA.

OBSERVED

The following granular zones have been observed beyond the static ground water level with the help of Advanced Electronic Geophysical Logger

Depth Range In Mtrs.		Length	Nature Of Samples	Expected
(B.G.L.)		(Mtrs.)		Water Quality
0.00	5.00	5.00	Clay	
5.00	15.00	10.00	Fine Medium Sand	
15.00	20.00	5.00	Clay	
20.00	27.00	7.00	Medium Sand	
27.00	31.00	4.00	Clay	
31.00	37.00	6.00	Medium Sand	Good
37.00	61.00	24.00	Clay	
61.00	71.00	10.00	Medium Sand	Good
71.00	110.00	39.00	Clay	
110.00	122.00	12.00	Medium Sand	Good
122.00	155.00	33.00	Clay	

For Supreme Water Sources

Amounted

Prop.