

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL
ELECTOLOGGING REPORT

Ref No:- 520

Date:- 31-12-2022

NAME OF SITE

Gram Panchayat- Chhateni

BLOCK- Nigohi

DISTT- Shahjahanpur

NAME OF AGENCY


M/s NCC Ltd.
Shahjahanpur



GROUND WATER SURVEY CONSULTANCY
Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy
Agra



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- CHHATANI, BLOCK- NIGOHI, DISTT- SHAHJAHANPUR
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 130 mtrs. depth. and Logged depth 130 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahjahanpur.

On the request of M/S NCC Ltd., Shahjahanpur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 31.Dec.2022.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 15	10	Clay kankar	
3.	15 - 31	16	Medium sand	Medium
4.	31 - 40	9	Clay kankar	
5.	40 - 56*	16	Medium sand	Medium
6.	56 - 61	5	Clay kankar	
7.	61 - 69*	8	Medium sand	Medium
8.	69 - 77	8	Clay kankar	
9.	77 - 96*	19	Medium sand	Medium
10.	96 - 110	14	Clay kankar	
11.	110 - 120*	10	Medium sand	Medium
12.	120 - 130	10	Clay kankar	



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

Rho s
 M16 (SN)
 NS-LL(N)
 LAT

157991 G.S. Cheater Box
 157992 G.S. Cheater Box
 157993 G.S. Cheater Box
 157994 G.S. Cheater Box
 157995 G.S. Cheater Box
 157996 G.S. Cheater Box
 157997 G.S. Cheater Box
 157998 G.S. Cheater Box
 157999 G.S. Cheater Box
 158000 G.S. Cheater Box

SP (m V)

