

Ref : MTL/WL/23-24/345

Date : 22.07.2023

REPORT ON GEO-PHYSICAL RESISTIVITY LOGGING OF BOREHOLE

A deep borehole was drilled by working agency M/s. GVPR ENGINEERING LIMITED as a part of their scope of work of development of Tubewell under Jal Jeevan Mission Project of SWSM, MTL conducted a Geophysical Continuous logging in the above borehole.

Village Name	Goora
Block	Umarda
District	Kannauj, U.P.
Logged Depth	196.1 Mtr BGL
Type of Log	Continuous well logger (SP, N16 (SN), N64 (LN) & LAT)
Machine Used	IGIS
Logging Date	21.07.2023

The following aquifer zones have been deciphered with the help of logging machine.

Sr. No.	Depth Range (mtr BGL)	Thickness (mtr)	Expected Quality
1	14 – 18	4	Good
2	31 – 43	12 ✓	Good
3	46 – 49	3 ✓	Good
4	79 – 87	8 ✓	Good
5	109 – 113	4	Good to Moderate

Rw – 15.7 Ohm mtr and Rm – 17.0 Ohm mtr

For Geo-Technical Consultant,



Authorised Signatory



