

# M/s Mahalaxmi Tubewell

3

Pukhrayan Kanpur 9935299290  
Geophysical Well Logging Report

Ref No 379

Date 22/01/2022

Site Location :- Village - Singhpur Sidhpura  
District :- Kasganj  
Logged Depth :- 127 M BGL  
Discharge :- 750 LPM  
Water Level :- 4+-1 Mtr  
Date of Logging :- 22/01/2022  
Types of Log :- S.P & Resistivity  
Logger used :- IGIS

The following permeable granular zones have been deciphered with the help of Electrical Logger.

Depth Range From M.B.G.L.	Depth Range M.B.G.L.	Thickness Mtrs.	Inferred Lithology	Quality of G.W.
0	15	15	Surface Clay with Fine sand and Kankar	
15	33	18	Fine to Medium sand	Good
33	62	29	Sandy Clay	?
62	65	03	Fine to Medium sand	Good
65	78	13	Clay	
78	102	24	Fine to Medium Sand	Good
102	122	20	Sandy Clay	
122	127	05	Fine Sand	Good

Verified as per logs provided.

Note - 1) 33-62 mbgl - interpreted lithology should re-checked.  
2) Groundwater quality mentioned in this report is as per logger machine calibration and accordingly interpreted by firm.

*[Signature]*

Dr. R. Srinivasa Chary  
(Geologist)

6/8/22  
ASSISTANT GEOLOGIST  
YATRIK MANDAL  
U.P. JAL NIGAM (RURAL)  
PRAYAGRAJ