



SUPREME WATER SOURCES.
TUBEWELL ENGINEERS
& CONSULTANTS

SUPREME WATER SOURCES.

TUBEWELL ENGINEERS & CONSULTANTS

Regd. Office: CHD. Road, Ekta Colony, Opp. Bhabat Petrol Pump, Rajpura (PB.)
SERVICE : Digital Electronic Well Logger upto 600 m
Resistivity Survey upto 1000 m Survey for Rain Harvesting Wells.
Mobile : 9888600462, 75080-00047 E-mail: supremewater8886@gmail.com

BOREHOLE DRILLED AT SITE G.P BAWAN SARAI, BLOCK KOTWALI, DISTT. BIJNOR (UP)

Drilled Depth :- 160 m
Logg Depth :- 159 m
Water Level :- 2 m (Approx.)
Date :- 28/09/2023

Name of Agency:- M/S L.C Infra

OBSERVED

The following granular zones have been observed beyond the static ground water level with the help of Advanced Electronic Geophysical Logger

Depth Range In Mtrs. (B.G.L.)		Length (Mtrs.)	Nature Of Samples	Expected Water Quality
0.00	1.00	1.00	Clay	
1.00	30.00	29.00	Medium Coarse Sand	Good
30.00	32.00	2.00	Clay	
32.00	66.00	34.00	Sand with Stones	Good
66.00	68.00	2.00	Clay Stones	
68.00	78.00	10.00	Sand with Boulder	Good
78.00	89.00	11.00	Clay with Boulder	
89.00	103.00	14.00	Sand with Boulder	Good
103.00	117.00	14.00	Clay with Boulder	
117.00	125.00	8.00	Sand with Boulder	Good
125.00	135.00	10.00	Clay with Boulder	
135.00	136.50	1.50	Sand with Boulder	Poor
136.50	146.50	10.00	Clay	
146.50	147.50	1.00	Sandy Clay Mix	
147.50	159.00	11.50	Clay	

For Supreme Water Sources

Anandjeet
Prop.