

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date..15.4.23.....

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES


Name Of Agency- L C Infra Pvt Ltd IRS Enterprises

Village - Bamnola Block - Mahaur

District - Agra Logging Depth - 150 mtr

Drilling Depth - 150 mtr Water Level - 10 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface soil	
2	5-10	Dry Sand.	
3	10-30	chy loam	
4	30-70*	Medium Sand	Medium
5	70-75	chy loam	
6	75-85*	Medium Sand	Medium
7	85-100	chy loam	
8	100-106*	fine to med. Sand	Medium
9	106-110	chy loam	
10	110-125	Medium Sand	Medium
11	120-132	chy loam	
12	132-150*	Medium Sand & clay	Medium
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

Sanku
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.