

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 28-06-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- LC Infra Surandar
Village - Maya bala Block- Kotwali
District- Bijnor Logging Depth- 160.mtr.
Drilling Depth- 165.mtr. Water Level- 26.mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 15	clay Konkaz	
3	15 - 27	Sand & Konkaz	
4	27 - 40	clay Konkaz	
5	40 - 46	Fine Sand	
6	46 - 53	clay Konkaz	
7	53 - 57*	Fine to med. Sand	Good
8	57 - 68	clay Konkaz	
9	68 - 75	Sand & Konkaz	Good
10	75 - 81	clay Konkaz	
11	81 - 87*	medium Sand	Good
12	87 - 99	clay Konkaz	
13	99 - 102	Fine Sand	Good
14	102 - 107	clay Konkaz	
15	107 - 112*	Sand & Konkaz	Good
16	112 - 134	clay Konkaz	
17	134 - 139*	medium Sand	Good
18	139 - 150	clay Konkaz	
19	150 - 157*	Sand & Konkaz	Good
20	157 - 160	clay Konkaz	
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

V. B. Pr.
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.