

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 29.4.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONNES

Name Of Agency..... L.C. Infra Shivam kumar
 Village..... Maderapur Banuani Block..... Allepbur
 District..... Bijnor Logging Depth..... 155 mtr
 Drilling Depth..... 160 mtr Water Level..... 9 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface soil	
2	5-15	dry kankar	
3	15-25	fine to med sand	Med + good
4	25-33	dry kankar	
5	33-47	medium sand	Med + good
6	47-53	dry kankar	
7	53-100	medium sand	Med + good
8	100-120	dry kankar	
9	120-151	medium sand	Med + good
10	151-155	dry kankar	
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Smt
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.