

**GROUND WATER SURVEY CONSULTANCY**  
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

**GEO-PHYSICAL WELL  
ELECTOLOGGING REPORT**

Ref No:-B-2581

Date:- 11-12-2023

**NAME OF SITE**

GRAM PANCHAYAT- Jhirjhirwa

BLOCK- Jamunaha

DISTT- Shravasti

**NAME OF AGENCY**

M/s MB Traders Shravasti



**GROUND WATER SURVEY CONSULTANCY**

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc\_agra@yahoo.com

**ISO ; 9001 : 2015**

Ground Water Survey Consultancy



# REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- JHIRJHIRWA, BLOCK- JAMUNAHA, DISTT- SHRAVASTI  
UNDER  
JAL JIVAN MISSION

## Introduction :

A Deep bore hole was drilled 165 mtrs. depth. and Logged depth 155 mtrs. at above site. Was drilled by M/s MB Traders, Shravasti.

On the request of M/s MB Traders, Shravasti. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 11.Dec.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major Aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

Mud Resistivity = 20.23 Ohms.

Drilling Water Resistivity = 21.40 Ohms.

Approx Water Level = 5 Mtr

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 11	6	Fine sand	
3.	11 - 20	9	Clay kankar	
4.	20 - 22	2	Fine sand	
5.	22 - 25	3	Clay kankar	
6.	25 - 30	5	Fine to Medium sand	Good
7.	30 - 35	5	Clay kankar	
8.	35 - 37	2	Fine to Medium sand	Good
9.	37 - 47	10	Clay kankar	
10.	47 - 81*	34	Medium sand & kankar	Good
11.	81 - 103	22	Clay kankar	
12.	103 - 125*	22	Medium sand	Good
13.	125 - 145	20	Clay kankar	
14.	145 - 155*	10	Medium sand	Good

Ground Water Survey Consultancy



### **Conclusions and Recommendations :-**

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (\*) appear to be aquifer zones for possible Development of tube well.
3. The Quality of water is expected Good.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.





