

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
 Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 11.4.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- LC Infra Pvt Ltd IRC Enterprises
 Village- Sarwanpur Block- Najibabad
 District- Bijnor Logging Depth- 147 mb
 Drilling Depth- 160 mb Water Level- 11 mb

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface soil	
2	5-17	fine sand	
3	17-26	Medium Sand	Medium
4	26-32	clay loam	
5	32-38	fine to medium sand	medium
6	38-52	clay loam	
7	52-65*	Medium Sand	Medium
8	65-80	clay loam	
9	80-90*	medium sand	Medium
10	90-96	clay loam	
11	96-105*	medium sand	Medium
12	105-110	clay loam	
13	110-115*	Medium Sand	Medium
14	115-126	clay loam	
15	126-140*	Medium Sand	Medium
16	145-147	clay loam	
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Singh
 Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.