

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
 Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com


Ref No. Date 11-4-23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- LC Infra Tech Parihar Enterprises
 Village- Ram Nagar Gopalwala Block- Ajzabet
 District- Bijnor Logging Depth- 148 mts
 Drilling Depth- 150 mts Water Level- 15 mts

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface soil	
2	5 - 10	clt	
3	10 - 19	Medium Sand	Medium
4	19 - 25	clt layer	
5	25 - 35	Medium Sand	Medium
6	35 - 40	clt layer	
7	40 - 48	Medium Sand	Medium
8	48 - 60	clt layer	
9	60 - 79	Medium Sand	Medium
10	79 - 85	clt layer	
11	85 - 99	fine Red soil	Medium
12	99 - 104	clt layer	
13	104 - 120	Medium Sand	Medium
14	120 - 125	clt layer	
15	125 - 128	fine Red soil	Medium
16	128 - 145	clt layer	
17	145 - 148	Sandy clay	
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

[Signature]
 Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.