



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.

Date 25-04-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT


DETAIL OF WATER BEARING ZONES

Name Of Agency- L.C. Infra Brothers Construction
 Village- Shahapur Sukkha Block- Kiratpur
 District- Bijnor Logging Depth- 160 mtr.
 Drilling Depth- 160 mtr. Water Level- 12 mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-13	Dry Sand	
3	13-25	Fine Sand	
4	25-28	Kankar	
5	28-35	Fine to med. Sand	Good
6	35-40	clay Kankar	
7	40-65*	medium Sand	Good
8	65-68	clay Kankar	
9	68-90*	medium Sand	Good
10	90-100	clay Kankar	
11	100-115*	Fine to med. Sand & Kah.	Good
12	115-118	clay Kankar	
13	118-150*	medium Sand & Kah.	Good
14	150-160	clay Kankar	
15			
16			
17			
18			
19			
20			
21			
22			
23			

* Expected Water Bearing Zone

For Ground Water Survey Consultancy


Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.