

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL
ELECTROLOGGING REPORT

Ref No:-A-2250

Date:- 26-11-2023

NAME OF SITE

GRAM PANCHAYAT- Papgaon

BLOCK- Bisauli

DISTT- Badaun

NAME OF AGENCY

M/s PNC-SPML-JV
Badaun



GROUND WATER SURVEY CONSULTANCY


Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy
Agra



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- PAPGAON, BLOCK- BISAULI, DISTT- BADAUN
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 140 mtrs. depth. and Logged depth 137 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Badaun.

On the request of M/S PNC-SPML-JV, Badaun. a Geophysical well Logging is conduct at above bore hole using IGIS Well Logger on 26.Nov.2023.

Logging Para meters - Self potential, short normal (N-16). Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 15	10	Dry sand	
3.	15 - 20	5	Clay kankar	
4.	20 - 25	5	Medium sand	Medium
5.	25 - 30	5	Clay kankar	
6.	30 - 45	15	Medium sand	Medium
7.	45 - 60	15	Clay kankar	
8.	60 - 85*	25	Medium sand	Medium
9.	85 - 95	10	Clay kankar	
10.	95 - 103*	8	Medium sand	Medium
11.	103 - 113	10	Clay kankar	
12.	113 - 129*	16	Medium sand	Medium
13.	129 - 137	8	Clay kankar	

V/S
Pr

Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geologist



Rho s

N16 (S/N)
N04(LIN)
LAT

Loggin Details

Logg 1: 17-18-2008
Blau, D. M. (Laden)
SP10001505
28 May 2008
12:00
UNITED STATES (AG)

Logger's Site

IGIS/S/02/22-23

SP (m V)

Logger Model

DMP1-2

Logger Owned by

GROUND WATER
SURVEY
CONSULTANCY
AGRA, UP, INDIA

