

संदेली कोतवाली

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 262006

Mob. : 9781163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date: 28.5.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency - L.C. Dabra Surendra Singh
 Village - Sarakhari Block - Kotwali
 District - Rajnagar Logging Depth - 162 mt
 Drilling Depth - 170 mt Water Level - 12 mt

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	Medium Sand	
3	10 - 49	Clay loams	
4	49 - 55	Medium Sand	Med + brw
5	55 - 60	Clay loams	
6	60 - 62	Medium Sand	Med + brw
7	62 - 66	Clay loams	
8	66 - 85	Medium Sand	Med + brw
9	85 - 105	Clay loams	
10	105 - 139	Medium Sand	Med + brw
11	139 - 145	Clay loams	
12	145 - 152	Medium Sand	Med + brw
13	152 - 156	Clay loams	
14	156 - 162	Medium Sand	Med + brw
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.