

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 31/2/23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency L.C Infra Project Pvt Ltd Surendra Sijal
 Village Salampur Block Mahthaur
 District Bagpat Logging Depth 160 mt
 Drilling Depth 160 mt Water Level 17 mt

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 12	Dry Sand	
3	12 - 25	Sandy clay	
4	25 - 30	claystone	
5	30 - 52'	Medium Sand	Good
6	52 - 55	claystone	
7	55 - 76'	Medium Sand	Good
8	76 - 80	claystone	
9	80 - 109'	fine to med sand	Good
10	109 - 112	claystone	
11	112 - 133'	medium sand	Good
12	133 - 144	claystone	
13	144 - 153'	medium sand	Good
14	153 - 160	claystone	
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Suresh
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.