

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

**GEO-PHYSICAL WELL
ELECTROLOGGING REPORT**

Ref No:- N-844

Date:- 18-01-2023

NAME OF SITE

Gram Panchayat- Jamunia Khanpur BLOCK- Banda DISTT- Shahjahanpur

NAME OF AGENCY

M/s NCC Ltd.
Shahjahanpur



GROUND WATER SURVEY CONSULTANCY
Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO 9001:2015

Ground Water Survey Consultancy
Agra

REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- JAMUNIA KHANPUR, BLOCK- BANDA,
DISTT- SHAHJAHANPUR
UNDER
JAL JIVAN MISSION


Introduction :

A Deep bore hole was drilled 130 mtrs. depth. and Logged depth 130 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahjahanpur.

On the request of M/S NCC Ltd., Shahjahanpur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 18.Jan.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 6	1	Dry sand	
3.	6 - 30	24	Clay kankar	
4.	30 - 40	10	Medium sand	Medium
5.	40 - 51	11	Clay kankar	
6.	51 - 60*	9	Medium sand	Medium
7.	60 - 62	2	Clay kankar	
8.	62 - 72*	10	Medium sand	Medium
9.	72 - 75	3	Clay kankar	
10.	75 - 84*	9	Medium sand	Medium
11.	84 - 95	11	Clay kankar	
12.	95 - 121*	26	Medium sand & kankar	Medium
13.	121 - 126	5	Clay kankar	
14.	126 - 130*	4	Medium sand	Medium



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

Rho a
 N16 (SN)
 NS4(LN)
 LAT

Logging VI Jamuna
 Khanpur block,
 Banda Dist.,
 Shahjahanpur
 LOGGERSHIP
 18 Jan 2023
 18.13
 Uttarakh Gupta (RS)

SP (mV)

