

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

**GEO-PHYSICAL WELL
ELECTROLOGGING REPORT**

Ref No:-A-2248

Date:- 25-11-2023

NAME OF SITE

GRAM PANCHAYAT- Fatehpur

BLOCK- Bisauli

DISTT- Badaun

NAME OF AGENCY

M/s PNC-SPML-JV
Badaun



GROUND WATER SURVEY CONSULTANCY


Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- FATEHPUR, BLOCK- BISAULI, DISTT- BADAUN
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 130 mtrs. depth. and Logged depth 127 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Badaun.


On the request of M/S PNC-SPML-JV, Badaun. a Geophysical well Logging is conduct at above bore hole using IGIS Well Logger on 25.Nov.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 15	10	Dry sand	
3.	15 - 30	15	Clay kankar	
4.	30 - 47	17	Medium sand	Medium
5.	47 - 50	3	Kankar	
6.	50 - 79*	29	Medium sand	Medium
7.	79 - 85	6	Clay kankar	
8.	85 - 93*	8	Medium sand	Medium
9.	93 - 110	17	Clay kankar	
10.	110 - 115	5	Fine sand	Medium
11.	115 - 127	12	Clay kankar	

Ground Water Survey Consultancy

Agra



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geologist



Rho a
N 16(SN)
N 64(LN)
LAT

Logging GP Instrument Block
Station Data Block
SP LOGGING
25 Nov 2023
16:18
Instrument: Gura 40G

Logger SI No:
KJIS/S/02/22-23

Logger Model:
SP

DNPL-2

Logger Owned by:
GROUND WATER
SURVEY
CONSULTANCY
AGRA, UP, INDIA

