



# GLOBAL GROUND WATER CONSULTANTS

84-III Floor, Humayunpur, Safdarjung Enclave, New Delhi - 110 029

Mobile : 9818 888 824, 9818 007 038

E-mail : srikanthchukka.c23@gamil.com, ravikanth44@yahoo.com

Pioneer

## GEOPHYSICAL ELECTRICAL LOGGING REPORT AT

Tubewell No. : .....


Date : 3.01.2022

Village : Manota

Block : Kasganj

District : Kasganj

Depth in Metres	Expected Litholog	Expected Water Quality
0-3m	Surge soil	
3-15	Fine sand	
15-20	clay	
20-29 <sup>m</sup>	medium sand	good
29-36 <sup>m</sup>	Fine sand	good
36-45	clay	
45-63 <sup>m</sup>	medium to coarse sand	good
63-78	clay kankar	
78-84 <sup>m</sup>	medium sand	good
84-90	clay	
90-97 <sup>m</sup>	medium sand	good
97-105	clay	
105-110 <sup>m</sup>	medium sand	good



For Global Groundwater Consultants

⊗ EXPECTED WATER ZONE

▽ WATER LEVEL : 5.11 METRES

आथशास आथश

*Srikanth*  
M. RAJ KANTH  
3/1/2022