


26

STRATA CHART & ACTUAL ASSEMBLY CHART OF TUBEWELL

NAME OF SCHEME :- ASOHANA
 NAME OF SITE :- ASOHANA
 NAME OF COMPANY :- PNC-SPML JV

BLOCK :- FATEHPUR
 DISTRICT :- BARABANKI



| | | | |
|---|--------------------|---|------------|
| 1 | BORE SIZE | = | 600*450 MM |
| 2 | ASSEMBLY SIZE | = | 300*150 MM |
| 3 | DRILLING DEPTH | = | 165 MTR |
| 4 | LOGGING DEPTH | = | 165 MTR |
| 5 | DATE OF LOGGING | = | 03.07.2023 |
| 6 | DATE OF LOWERING | = | 05.07.2023 |
| 7 | REQUIRED DISCHARGE | = | 510 LPM |

| S. NO. | DEPTH RANGE (Mbg) | Thickness (M) | Remarks (Quality of formation/Water) |
|--------|-------------------|---------------|---|
| 1 | 20-25 | 5 | GOOD |
| 2 | 45-64 | 16 | GOOD |
| 3 | 72-78 | 6 | GOOD |
| 4 | 80-87 | 7 | GOOD |
| 5 | 102-109 | 7 | GOOD |
| 6 | 113-122 | 9 | GOOD |
| 7 | 125-128 | 3 | GOOD |
| 8 | 133-140 | 7 | GOOD |

| S. NO. | DESCRIPTION | REMARKS |
|--------|---------------------------|---------|
| 1 | Total 300 mm plain pipe | 45.01 |
| 2 | Total 150 mm plain pipe | 56.77 |
| 3 | Total 150 mm slotted pipe | 24.10 |
| 4 | Reducer 300 mm X 150 mm | 0.20 |
| 5 | Total Assembly lower | 126.08 |
| 6 | AGL | 0.50 |
| 7 | BGL | 125.58 |

| | | | |
|---------------|--------------|----------------|--------------------|
| | | | |
| PREPARED BY | CHECKED BY | RECOMMENDED BY | APPROVED BY |
| PNC SPML - JV | JR. ENGINEER | ASS. ENGINEER | EXECUTIVE ENGINEER |